



**MARINE BIOLOGICAL & CHEMICAL  
CONSULTANTS**

**FOOD TECHNOLOGY CENTRE, LÔN PENMYNYDD,  
LLANGFNI, YNYS MÔN, LL77 7HY.**



Telephone: 01248 751215  
751216

Fax: 01248

## Certificate of Analysis

Certificate No: MB7236/25/2291W

**Project Description: Microbiological Analysis**

**Date:** 19/08/25      **Client:** Steve Simonds  
Conwy County Borough Council  
PO Box 1,  
Conwy, LL30 9GN

**Your Ref:** -

Date & Time Sampled: 15/08/25 09:00

**Date of Receipt:** 15/08/25

**Date of Analysis:** 15/08/25      **For Attention of:** PO00067203

Results are as follows:

**Sample No: 2512552 SS3807 pen Y Clogwyn Kitchen Tap**

Coliforms (confirmed)	<b>(WI/B01)</b>	None found in 100 ml
<i>E.coli</i> (confirmed)	<b>(WI/B01)</b>	None found in 100 ml
Enterococci (presumptive)	<b>(WI/B02)</b>	None found in 100 ml
Sulphite reducing Clostridia	<b>(WI/B06)</b>	None found in 100 ml

**Aerobic Plate Count (WI/B04):**

37°C/1 day	< 1 cfu in 1 ml
22°C/3 day	< 1cfu in 1 ml

*B Egan*

**Mr B. Egan  
General Manager**

*J A Egan*

**Mrs J. A. Egan  
Technical Manager**

This laboratory report reflects the quality of the sample as supplied to our laboratory. MBCC accept no responsibility for any course of action arising from the interpretation of this report.

Tests marked ‡ in this Certificate are not included in the UKAS Accreditation for our laboratory.

\* certificate re-issued due to typographical error.